



TEST REPORT

Sample Name:	Drinking Water	Report No:	STH/2026/04/24/02
Customer Name:	Sri Chaitanya techno School	Sample Quantity:	2 Ltr.
Customer Address:	Branch Noida-5 KP - 1 GREATER NOIDA Gautam Budh Nagar, UP	Sample Condition:	Good
Sample Received By:	Pramod Kumar(From Lab)	Temperature:	25°C ± 2
U.L.R No.:	TC14633026042402F	Humidity:	55% ± 10
Sample Received On:	28/07/2026	Ref. No.:	-Nil-
Tested Location:	At Laboratory	Duration of Testing:	28/07/2026-06/08/2026
		Reporting Date:	06/08/2026

S.No	Test Parameter	Test Result	Requirement as per IS:10500:2012, Acceptable/Permissible Limit in the absence of alternate source	Test Method
<i>Chemical Parameters</i>				
1.1	Color, Hazen units	2	5/15	IS: 3025-(P-4)
2.1	Odour	Agreeable	Agreeable/ Agreeable	IS: 3025-(P-5)
3.1	pH @ 27°C	7.25	6.5-8.5/No relaxation	IS: 3025-(P-11)
4.1	Taste	Agreeable	Agreeable/ Agreeable	IS: 3025-(P-8)
5.1	Turbidity (NTU), Max.	<1	1/5	IS: 3025-(P-10)
6.1	T.D.S (mg/l), Max.	49	500/2000	IS: 3025-(P-16)
7.1	Total hardness (mg/l), Max.	34.0	200/600	IS: 3025-(P-21)
8.1	Chloride (mg/l), Max.	26.5	250/1000	IS: 3025-(P-32)
9.1	Residual free chlorine (mg/l), Max.	NIL	0.2/1	IS: 3025-(P-26)
10.1	Iron (mg/l), Max.	0.014	1.0/No Relaxation	IS: 3025-(P-53)
11.1	Fluoride (mg/l), Max.	0.016	1.0/1.5	IS: 3025-(P-60)
12.1	E.coli Bacteria	Not detected	Shall not be detectable in any 100ml Sample	IS:1622-1981
13.1	Total Coliform Bacteria	Not detected	Shall not be detectable in any 100ml Sample	IS:1622-1981

End of Report

Page 1 of 1

Verified (Supreme Test House)

 (Quality Manager)

Authorized Signatory

 (Technical Manager)

Note: (1) The report refers only to the particular sample(s) submitted for testing. (2) This report shall not to be reproduced except in full without approval of the laboratory or in part and cannot be evidence in the court of Law. (3) Any discrepancy observed in the test report shall be brought in to the notice of the laboratory within week. (4) Results applied to the sample as received in the laboratory submitted by customer